

Diesel generating set

AGLP640P

400V/50Hz Main power//Perkins 4006-23TAG3A



ISO14001:2015

ISO9001 :2015

OHSAS 18001:2007

Product features

// Operative norm:

- ISO 8528:AC generator set driven by reciprocating internal combustion engine
- IEC 60034-1:Basic technical requirements for rotating motors
- YD/T 502: Communication diesel generator set
- GB/T 20136-2006 General test method for internal combustion engine power stations

// Merit:

- ◇ Integrated building block structure design, small volume, compact structure, sophisticated technology;
- ◇ Few parts, light weight, low failure rate and low maintenance cost;
- ◇ Supercharging and supercharging intercooling technology as the leading products, strong power;
- ◇ High-performance damping system and rigid base, small vibration;
- ◇ Efficient fuel supply system and air intake system, fuel atomization and air mixing more fully, more complete combustion, lower emissions;
- ◇ Standardized design, comprehensive and intelligent products, parts and components have strong versatility, easy installation and easy maintenance;
- ◇ maintenance-free battery, with fast start performance;

Technical parameters of the unit

// Generator set

Generator model:	AGLP640P	Main power (kW):	640
Standby power (kW):	700	unit capacity (kVA):	800
Rated speed (rpm):	1500	frequency (Hz):	50
Rated voltage (V):	400	rated current (A):	1154.7
Power factor (cos ϕ):	0.8(lag)	Wiring mode:	3 phase 4 wire
Generator weight (kg)	12334	Minimum smoke pipe diameter (mm)	1 \times ϕ 165
Air intake (m ³ /min):	1414	Air exhaust (m ³ /min):	1350
Generator size (mm): 6058L \times 2438W \times 2591H Recommended base size (mm): 4500L \times 2000W			

Unit performance index (G2)

Parameter		unit	Performance index
Frequency drop		%	≤ 3
Steady state frequency band		%	≤ 0.5
Relative frequency setting drop range		%	≥ 3.5
Relative frequency setting rise range		%	≥ 2.5
Transient frequency deviation	100% sudden power reduction	%	$\leq +10$
	Surge power		≤ -7
Frequency recovery time		s	≤ 3
Relative frequency tolerance band		%	2
Steady-state voltage deviation		%	$\leq \pm 1$
Voltage unbalance degree		%	1
Transient voltage deviation	100% sudden power reduction	%	$\leq +20$
	Surge power		≤ -15
Voltage recovery time		s	≤ 4
Voltage modulation		%	0.3
Relative voltage setting range		%	$\leq \pm 5$
Voltage setting rate of change		%/s	0.2~1
Telephone harmonic factor	THF	%	< 2
Telephone influence	TIF	—	< 50



factor

Engine technical parameters

// Engine

Manufacturer: Perkins
Model: 4006-23TAG3A
Engine structure: four-stroke
Number: 6/V
Displacement: L 22.921
Cylinder diameter: mm 160
Stroke: mm 190
Compression ratio: 13.6:1
Speed: rpm 1500
Primary/standby power: kW 705/786
Speed regulation mode: ECM
Cooling method: closed water cooling
Dry weight (engine only): kg 2524

// Start the system

Starting rated power: kW 9
Starting rated voltage: V DC24

// Fuel system

Fuel injection form: high pressure common rail

// Fuel consumption

Engine output	L/h	g/kwh
100%	172	212.3
75%	132	206
50%	90	210
25%	NA	NA

// Intake system

Maximum allowable intake resistance
(clean filter element): kPa 1.25

Intake air flow: m³/min 64

// Lubrication system

Total lubrication system capacity: L 113

Maximum allowable oil temperature: °C 125

// Cooling system

Engine coolant volume: L 120

Coolant flow: L/min 142

// Exhaust system

Maximum exhaust back pressure: kPa 6

Exhaust flow: m³/min 193

Exhaust temperature: °C 500


Technical parameters of generator

//Dynamo

*50Hz, AC400V, cos φ = 0.8

MODEL	Rated power (kW)	Standby power (kW)	Mechanical efficiency (%)	Insulation	Class of protect	Weight (kg)
LEROYSOMER: TAL A49C	656	728	93	H/H	IP23	1653

Size and weight



* The above figure is for reference only, the actual size and weight are subject to the final design drawing.

Model	Engine model	size (L×W×H) (mm)	Dry weight (kg)	Wet weight (kg)
THLP640P	4006-23TAG3A	6058×2438×2591	12114	12314

Special instructions

// Main power (PRP) is the maximum power that the unit can run continuously with variable load under standard environment (atmospheric pressure, relative humidity, ambient temperature), and the overload of 10% is allowed to run for 1h every 12h.

// Working conditions and power correction:

Altitude: ≤1000m (> 1000m), need to do power correction; Power reduction by 10% per 1000m increase)

Ambient temperature: 40℃ (when > 40℃, power correction is required)

Relative humidity: ≤60%

When the field use conditions of the diesel generator set do not meet the above conditions, the output power of the unit should be corrected, and the final correction coefficient, please refer to the detailed technical data of the corresponding engine and generator.

SHANGHAI AGRIPower INTIL CO., LTD
Bldg 38th, No. 900 Haili Rd,
Jinshan District, Shanghai 201508. China
T: +86 21 67290268 F: +86 21 67290269
Web: www.china-agripower.com